

**Demo Door Co.**

345 West Industrial Road

Anytown, USA 58466

p:(555) 555-5555 | f:(555) 444-4444

service@demodoorco.com

**Door - PM Inspection**Report Date **May 19, 2015 14:09 MDT***This report summarizes inspection results including grades, notes and photographs.*

Customer:	<b>Richardson Brothers</b>	Building:	<b>Refurb Center</b>
Address	17532-14 Ave, Pleasantville, CO, US - 86514		
Contact 1:	Jim Anderson	Contact 2:	Nathan Samuels
Phone:	555-555-4444	Phone:	555-555-2222
Email:	jim.anderson@rbros.com	Email:	nathan.samuels@rbros.com

Door ID & Description
Door ID <b>0001285</b>
Description PUR 24' x 20' E/O

Inspection Date/Time ID			
Created	<b>Jan 15, 2015</b>	14:09	Not SafedoorPM Compliant
Finished	Apr 22, 2015	7:29	Not Posted
Signature			

Door Notes	657, mechanic shop door #2
------------	----------------------------

DOOR			
GRADE	INSPECTION ELEMENT	NOTES	PHOTO
Pass	Cables, cable anchors, bottom brackets		
Fail	Rollers, roller brackets, end framing, center hinges	[2015-01-15 14:46] FW: Top left-hand side bracket bent, needs to be replaced [2015-01-15 14:46] CW: Multiple hinges loose retightened	YES (2)
Pass	Struts, span braces	[2015-01-15 14:30] CW: Multiple span braces pulled away from panels reattached and added more tech screws	
Pass	Vertical track, brackets		
Pass	Sections, joints, gaskets		
Pass	Windows, glazing		
Pass	Shaft, couplers, drums	[2015-01-15 15:30] CW: Coupler set screws loose, tightened. Right-hand side drum set screws loose, tightened.	
Pass	Bearings, bearing plates		
Pass	Torsion springs		
Fail	Door level, balance	[2015-01-15 15:32] FW: Door heavy recommend two turns	
Pass	Horizontal track		
Pass	Pusher springs, bumpers, stops		
Pass	Back hanging		
Pass	Door safety labeling		

**Demo Door Co.**

345 West Industrial Road

Anytown, USA 58466

p:(555) 555-5555 | f:(555) 444-4444

service@demodoorco.com



**Door - PM Inspection**

Report Date **May 19, 2015 14:09 MDT**

*This report summarizes inspection results including grades, notes and photographs.*

DOOR			
Pass	Weatherstrip, U-rubber, top flap	[2015-01-15 15:35] FW: 3 inch bottom u rubber flattened, recommend replacing. bottom retainer okay	
Pass	Fail safe bottom brackets		
Pass	Door operation		

OPERATOR			
GRADE	INSPECTION ELEMENT	NOTES	PHOTO
Pass	Operator mounting and anchoring		
Pass	Spreader bar		
Pass	Drive gear		
Pass	Clutch (force), brake		
Pass	Limits		
Pass	Electrical, enclosure		
Pass	Manual release, emergency chain hoist		
Pass	Wall control station		
Pass	Operator safety labeling		
Pass	Protective operator cover		
Pass	Photo-eyes - primary	[2015-01-15 14:15] GN: Photo eyes have been removed. Door is in constant pressure mode to close	
Fail	Sensing edge - secondary	[2015-01-15 14:16] FW: Door needs Road hose	YES (1)

PHOTOS			
			
0001285	Rollers, roller brackets, end framing, center hinges	0001285	Rollers, roller brackets, end framing, center hinges
			
		0001285	Sensing edge - secondary